AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT					Contract Number	Page of Pages	1	
2. Amendment/Modification Number			Requisition/P	ion/Purchase Request No.		5. Solicitation Caption Elevator Upgrade at DC General Core		
DCAM-12-CS-0132-002		10/2012				Building		
6. Issued By: Department of General Services Contract and Procurement Division 2000 14th Street, N.W., 5th Floor Washington, DC 20009	Code		7. Administe	ered	By (If other than line	3)		
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)					(X) 9A. Amendment of Solicitation No. DCAM-12-CS-0132			
					9B. Dated (See Item 11) 30-Mar-12			
					10A. Modification of			
Code	Facility 11. THIS ITEM ONLY APPLIES TO AMENDMEN				10B. Dated (See Item 13)			
The above numbered solicitation is Offers must acknowledge receipt					·	is extended. x is not ext	ended.	
following methods: (a) By comple	•		<u>:</u>			By acknowledging receipt of the	his	
amendment on each copy of the	-	•						
amendment number. FAILURE O								
PRIOR TO THE HOUR AND DAT							nange	
an offer already submitted, such of					r telegram makes refe	erence to the		
solicitation and this amendment, a 12. Accounting and Appropriation Dat	and is received prior i	to the opening hour	and date spec	ified				
72. Accounting and Appropriation Bat	a (ii required)							
					CONTRACTS/ORDE	RS,		
(X) A. This change order is issue	d pursuant to: (Speci	ify Authority)						
The changes set forth in Item								
B. The above numbered cont date, etc.) set forth in item 14	, pursuant to the auth	hority of 27 DCMR, (Chapter 47, Se			aying office, appropriation		
C. This supplemental agreem	ient is entered into pu	ursuant to authority of	of:					
D. Other (Specify type of mod	dification and authorit	y)						
E. IMPORTANT: Contractor	is not, x	is required to sign t	his document	and	return 6	copies to the issuing office.		
14. Description of amendment/modific	ation (Organized by	UCF Section headin	gs, including s	olicit	ation/contract subjec	matter where feasible.)		
The following solicition is hereby a	amended as follows	s:						
Pre-Bid Attendance Sheet - Att	tachment A							
2. Questions and Answers - Attac	chment B							
The proposal due date, time and	d nlace remains th	ha sama						
The proposal due date, time and	a piace remains u	ie same.						
Except as provided herein, all terms a	nd conditions of the	document reference	d in Item (9A c	or 10.	A) remain unchanged	and in full force and effect		
15A. Name and Title of Signer (Type of					ontracting Officer			
15B. Name of Contractor		15C. Date Signed	16B. District	t of C	Columbia	16C. Date	e Signed	
(Signature o	f person authorized to sign)			Q	W (Sign	ature of Contracting Officer)	4/10/2012	

Attachment A

GOVERNMENT OF THE DISTRICT OF COLUMBIA DEPARTMENT OF GENERAL SERVICES

ELEVATOR UPGRADE AT DC GENERAL CORE BUILDING

Questions and Answers For Elevator Upgrade at DC General Core Building DCAM-12-CS-0132

Question #1: Is the Contractor responsible to provide Temporary Restroom Facilities even if we would not need them?

Answer: Yes, the Contractor will not be allowed to use the clients' facilities.

Question #2: Can we retain the controllers and just replace the DC Gearless Machines if we can

find a vendor that still offers them?

Answer: This can be a deduct alternate.

Question #3: Can the Contractor use the machine room as the work area in lieu of providing a

260 ft long fence in the parking lot?

Answer: No, the fence will also be used to provide parking for the Contractor as well as the

COTR and his/her consultants.

Question #4: Do the drawings need to be stamped and certified by an Architect?

Answer: Yes.

Question #5: Please provide the name of the Third Party Inspector the DCRA will approve, so

we can see what their costs are.

Answer: See the DCRA website www.DCRA@dc.gov.

Question #6: Is it necessary to provide Video Tape Training CD's?

Answer: Yes.

Question #7: Is this project tax exempt?

Answer:

Yes.

Question #8: Is a storage container required?

Answer:

No.

Question #9: Does the time allocated for this project include just installation time and not

material manufacturing/deliver?

Answer:

Yes, the time includes everything.

Question #10: Who is responsible for the interim maintenance on this project?

Answer:

The awarded Contractor shall plan in their proposal to maintain the maintenance of all elevators until substantial completion and acceptance by the District.

Question #11: Is a warranty required?

Answer:

The Contractor should include in their proposal a 1 year warranty as well as a 1 year maintenance agreement.

Question #12: Is a free maintenance period required?

Answer:

Yes, 1 year from substantial completion.

Question #13: Please define the allocated amount of time – Page 10 states 180 and page 12 states

all work to be completed in 120 days.

Answer:

The allocated amount of time is a 180 days total for Design, Construction and

Closeout.

Question #14: Please clarify, Page 23 G.1.15.1 states that the Contractor will submit to the COTR not later than seven (5) days a schedule?

Answer: Approved CPM Schedule should be submitted within seven (7) days of NTP.

Question #15: Page 25 states that the Contractor shall employee watchpersons – G.17.4. Iis this required?

ı

Answer: Not required, but the Contractor is responsible for protecting all equipment until

turn over and accepted by the District.

Question #16: Page 25 states that the Contractor shall provide Lights – G.17.5. Is this required?

Answer: No, the Contractor should only provide lights as needed to fulfill the work.

Question #17: Will the District provide the Prolog and Primavera P6 Software?

Answer: The District will provide access to Prolog but not P6. The Contractor has the

option of using P6 or Microsoft Project for their schedule.

Question #18: Please clarify the cab interior you are requesting?

Answer: Stainless Steel Wall Panels

New ADA Compliant Handrails with the most current codes

New Luminous Drop Ceiling (Egg Crate)

Clad Front & Control Panel Wall, Transom and Strike Jamb with Stainless Steel

#4 Satin

New Heavy Duty MMA Flooring (Color to be selected by owner)

Question #19: Will DGS accept alternatives to the elevator controller manufacture?

Answer: The Contractor is free to submit voluntary alternates as long as they first reply to

the RFP.

Question #20: Can DGS include design alternatives in the proposal to include the following?

Answer:

The District will not be pursuing this option but the Contractor can submit a

voluntary alternate.

Question #21: Will DGS review the attached proposed elevator specifications for

implementation in the RFP?

Answer:

The District will not be pursuing this option but the Contractor can submit a

voluntary alternate.